

**Intertek** ETL SEMKO

## AUTHORIZATION TO MARK

This authorizes the application of the Certification Marks shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

**Applicant:** Sysgration Ltd.  
10F1, No. 868, Chung Cheng Road, Chung Ho, Taipei, Taiwan

**Contact:** Name: Mr. Jing Shyh Yeh Phone: 886-2-82217111

**Manufacturer:** Sysgration Nan-Kan Factory  
Zip 540, No. 26, North Industrial Rd., Nan-Kan Industrial Zone, Nan-Tou City, Nan-Tou County, Taiwan

**Party Authorized To Apply Mark:** (Same as Manufacturer)

**Report Issuing Office:** Intertek Testing Services Taiwan Ltd.


**Report No.:** CT06094

**Product Covered:** Utility Interactive Photovoltaic Inverter, Model Soleil 2000-120

**Description:** The product covered is an interactive-type Photovoltaic Inverter suitable for indoor and outdoor use. It shall be installed with a manufacturer supplied isolation transformer, Sysgration Ltd., Type SYST1201. The inverter has a NEMA type R3 enclosure. The unit is suitable for operating at -20 °C to 50 °C environment. The CPU used for the Digital Signal Processing is Texas Instrument, type TMS320LF2407. The software and firmware used for testing is Version 10.

**Standard(s):** Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (UL 1741, 1st Ed. Dated May 7, 1999-Revised November 7, 2005)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized to Apply Mark.

**Authorized by:**   
William T. Starr  
Certification Manager



**Date:** 30 Aug, 2006

**Control Number:** 3103612

This document supersedes all previous Authorizations to Mark for the noted Report number.

**Intertek Testing Services NA Inc.**  
165 Main Street, Cortland, NY 13045, USA  
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699

