

Intertek ETL SEMKO

AUTHORIZATION TO MARK

This authorizes the application of the Certification Marks shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

Applicant: Sysgration Ltd.
10F1, No. 868, Chung Cheng Road, Chung Ho, Taipei, Taiwan

Contact: Name: Mr. Jing Shyh Yeh Phone: 886-2-82217111

Manufacturer: Sysgration (Shenzhen) Ltd.
Egonling Village, Pinhu Town, Longgang, Shenzhen City, China

Party Authorized To Apply Mark: (Same as Manufacturer)

Report Issuing Office: Intertek Testing Services Taiwan Ltd.

Report No.: CT06122

Product Covered: Dry Type Isolation Transformer, Model SYST1201 and SYST2401

Description: The product covered by this report is a Dry Type Isolation Transformer for indoor and outdoor use. It is a single phase, winding ratio 1:1 for Model SYST1201 and 2:1 for Model SYST2401, suitable for max ambient 50 °C transformer. The product is considered as Class I equipment.

Standard(s): Dry-Type General Purpose and Power Transformer (ANSI/UL 1561, Third Edition, Rev. September 15, 2005)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized to Apply Mark.



Authorized by: for John Starr
William T. Starr
Certification Manager

Date: 21 Aug, 2006

Control Number: 3101303

This document supersedes all previous Authorizations to Mark for the noted Report number.

Intertek Testing Services NA Inc.
165 Main Street, Cortland, NY 13045, USA
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699

